



Section I- General Information

Space Name: No. 2 Fuel Oil (Diesel) Tank #19

Space Description: 50,000 gallon above ground storage tank labeled

Space No./ID: 021016

Tank #19, used for storage of No. 2 fuel oil (diesel). Tank is 20' tall with 24' diameter.

Space Location: COMBINED HEAT AND POWER PLANT (Adjacent to Plant Parking Area)

Contains one access hatch at top of tank and one access hatch at bottom of tank inside secondary containment.

Section II- Confined Space

Table with 4 columns: Question, Yes, No, Comments. Rows include: Can you enter and perform assigned work?, Are there limited/restricted means for entry or exit?, Is space not designed for continuous employee occupancy?

If answer to all three above are yes, the space in question is considered a confined space. If it is determined the space is a confined space, complete section II to determine if space is considered a permit required confined space.

Section III - Permit Required Confined Space

Table with 4 columns: Question, Yes, No, Comments. Rows include: Contains or has the potential to contain a hazardous atmosphere?, Contains a material that has the potential for engulfing the entrant?, Has an internal configuration such that an entrant could be trapped or asphyxiated by inwardly converging walls or by a floor which sloped downward and tapers to a smaller cross section?, Contains any other recognized serious safety hazard?

If the answer to any one of the above in section two is yes, the space in question is considered a permit required confined space.

Section IV - Comments/Other Please list or identify any additional comments or concerns below such as description of entry portal, access restrictions and/or traffic concerns, etc...

- Greater than 4' vertical travel Vertical entry through hatch located on top of tank
Horizontal Entry Horizontal entry through hatch located at bottom of tank

Can space be reclassified? Yes [ ] No [X]

Can alternate procedures be used? Yes [ ] No [X]

Name: Matthew Smith

Date: 11/20/2014



UNIVERSITY *of* NEW HAMPSHIRE

Confined Space Assessment Form

---