



Section I- General Information

Space Name: No. 2 Fuel Oil (Diesel) Tank Secondary Containment

Space Description: Secondary containment structure

Space No./ID: 021017

For 50,000 gallon No. 2 Fuel Oil (diesel) tank.

Space Location: COMBINED HEAT AND POWER PLANT (Adjacent to Plant Parking Area)

Section II- Confined Space

Table with 4 columns: Question, Yes, No, Comments. Rows include: Can you enter and perform assigned work?, Are there limited/restricted means for entry or exit?, Is space not designed for continuous employee occupancy?.

If answer to all three above are yes, the space in question is considered a confined space. If it is determined the space is a confined space, complete section II to determine if space is considered a permit required confined space.

Section III - Permit Required Confined Space

Table with 4 columns: Question, Yes, No, Comments. Rows include: Contains or has the potential to contain a hazardous atmosphere?, Contains a material that has the potential for engulfing the entrant?, Has an internal configuration such that an entrant could be trapped or asphyxiated by inwardly converging walls or by a floor which sloped downward and tapers to a smaller cross section?, Contains any other recognized serious safety hazard?.

If the answer to any one of the above in section two is yes, the space in question is considered a permit required confined space.

Section IV - Comments/Other Please list or identify any additional comments or concerns below such as description of entry portal, access restrictions and/or traffic concerns, etc...

- Greater than 4' vertical travel Access from ladder would be over top of containment from ladder platform
Horizontal Entry Access hatch located at base of secondary containment structure

Can space be reclassified? Yes [] No [X]

Can alternate procedures be used? Yes [] No [X]

Name: Matthew Smith

Date: 11/20/2014



UNIVERSITY *of* NEW HAMPSHIRE

Confined Space Assessment Form
