



Section I- General Information

Space Name: Plumbing Pit

Space Description: Approximately 8' deep plumbing

Space No./ID: 154003

Pit located in room B07B (closet off of occupied office

Space Location: ELLIOTT ALUMNI CENTER B07B

B07) with 12"x18" removable cover

Section II- Confined Space

Table with 4 columns: Question, Yes, No, Comments. Rows include: Can you enter and perform assigned work?, Are there limited/restricted means for entry or exit?, Is space not designed for continuous employee occupancy?

If answer to all three above are yes, the space in question is considered a confined space. If it is determined the space is a confined space, complete section II to determine if space is considered a permit required confined space.

Section III - Permit Required Confined Space

Table with 4 columns: Question, Yes, No, Comments. Rows include: Contains or has the potential to contain a hazardous atmosphere?, Contains a material that has the potential for engulfing the entrant?, Has an internal configuration such that an entrant could be trapped or asphyxiated..., Contains any other recognized serious safety hazard?

If the answer to any one of the above in section two is yes, the space in question is considered a permit required confined space.

Section IV - Comments/Other

Please list or identify any additional comments or concerns below such as description of entry portal, access restrictions and/or traffic concerns, etc...

[X] Greater than 4' vertical travel Approximately 8' deep
[] Horizontal Entry

Can space be reclassified? Yes [] No [X]

Can alternate procedures be used? Yes [] No [X]

Name: Matthew Smith

Date: 12/09/2014