



Section I- General Information

Space Name: Plumbing Pit

Space Description: 6'-7' deep plumbing/utility pit with

Space No./ID: 032020

Metal grate cover and fixed ladder access located beneath

Space Location: FIELD HOUSE G19

Laundry area.

Section II- Confined Space

Table with 4 columns: Question, Yes, No, Comments. Rows include: Can you enter and perform assigned work? (Yes X, Comments: Need to remove metal grate cover); Are there limited/restricted means for entry or exit? (Yes X, Comments: Fixed ladder access); Is space not designed for continuous employee occupancy? (Yes X)

If answer to all three above are yes, the space in question is considered a confined space. If it is determined the space is a confined space, complete section II to determine if space is considered a permit required confined space.

Section III - Permit Required Confined Space

Table with 4 columns: Question, Yes, No, Comments. Rows include: Contains or has the potential to contain a hazardous atmosphere? (Yes X, Comments: Oxygen Deficiency); Contains a material that has the potential for engulfing the entrant? (Yes X, Comments: Possibly water); Has an internal configuration such that an entrant could be trapped or asphyxiated...? (No X); Contains any other recognized serious safety hazard? (Yes X, Comments: Electrical from equipment in pit)

If the answer to any one of the above in section two is yes, the space in question is considered a permit required confined space.

Section IV - Comments/Other

Please list or identify any additional comments or concerns below such as description of entry portal, access restrictions and/or traffic concerns, etc...

[X] Greater than 4' vertical travel Pit is 6'-7' deep
[] Horizontal Entry

Can space be reclassified? Yes [] No [X]

Can alternate procedures be used? Yes [] No [X]

Name: Matthew Smith

Date: 04/02/2015