



Section I- General Information

Space Name: Hot Water Line Utility Pit

Space Description: Approximately 8' deep concrete pit

Space No./ID: 032022

Located under floor mats containing hot water supply and

Space Location: FIELD HOUSE 156

Return lines. Has 2'x2' access cover.

Section II- Confined Space

Table with 4 columns: Question, Yes, No, Comments. Rows include: Can you enter and perform assigned work?, Are there limited/restricted means for entry or exit?, Is space not designed for continuous employee occupancy?

If answer to all three above are yes, the space in question is considered a confined space. If it is determined the space is a confined space, complete section II to determine if space is considered a permit required confined space.

Section III - Permit Required Confined Space

Table with 4 columns: Question, Yes, No, Comments. Rows include: Contains or has the potential to contain a hazardous atmosphere?, Contains a material that has the potential for engulfing the entrant?, Has an internal configuration such that an entrant could be trapped or asphyxiated..., Contains any other recognized serious safety hazard?

If the answer to any one of the above in section two is yes, the space in question is considered a permit required confined space.

Section IV - Comments/Other

Please list or identify any additional comments or concerns below such as description of entry portal, access restrictions and/or traffic concerns, etc...

Greater than 4' vertical travel [X] Approximately 8' deep
Horizontal Entry [ ]

Can space be reclassified? Yes [ ] No [X]

Can alternate procedures be used? Yes [ ] No [X]

Name: Matthew Smith

Date: 04/02/2015